

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0026:179 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Model 4603-9101 annunciator. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as an annunciator for use with the following control units: Model 4100 (CSFM Listing No. 7165-0026:160 and 7170-0026:187) or Model 4020-8001 (CSFM Listing No. 7165-0026:178).

NOTE: Not suitable for use with Model 4100 fire alarm control unit when the control unit is configured for proprietary receiving service.

*Rev. 06-06-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager